

564-11

GEA-1094
Old Series Y-2129

INTERIOR ILLUMINATION

By

H. E. Mshan



ILLUMINATING ENGINEERING LABORATORY

General Electric Co.

Schenectady, N. Y.



GEA-1094
Old Series Y-2129

INTERIOR ILLUMINATION

By

H. E. Mahan

ILLUMINATING ENGINEERING LABORATORY

General Electric Co.

Schenectady, N. Y.

INTERIOR ILLUMINATION

The following data is offered as a brief summary of a few of the fundamental considerations underlying the design of interior lighting systems in order that salesmen not specializing on lighting equipment may have some familiarity with illumination and thus more efficiently serve the customer and the General Electric Company. Our consideration of the subject in this pamphlet must of necessity be very superficial.

AVOID GLARE

Glaring light sources are responsible for the failure of many lighting systems. Glare causes eye strain and fatigue, interferes with vision and increases the accident hazard. Glare may be caused by exposed light sources or contrasts in surface brightness. These may be avoided by properly shading the lamps and distributing the light uniformly within the field of view.

DISTRIBUTION OF LIGHT

The degree to which shadows are minimized is dependent upon the distribution of light. A diffused light softens shadows because it comes from many directions; a unidirectional light creates dark, sharp shadows. Each system has its field of application, a well diffused light best fulfilling the conditions of the workshop or office and a strongly directional light being required at times to give proper form to architectural features.

QUALITY OF LIGHT

The spectral composition of artificial light is important in many industries and for many purposes, as for example, where objects viewed under artificial light are to appear as they do under daylight. Inasmuch as the color of objects is dependent upon the quality of light incident upon them, it is necessary to give consideration to this question in operations requiring color discrimination.

INTENSITY

The intensity of illumination required is dependent upon the character of work or nature of the building. Sufficient intensity should be provided to enable the eye to function properly and to comfortably do that which is required of it. A study of conditions should, therefore, be made to determine what will constitute adequate illumination for the conditions at hand.

We show in Table No. 1 a guide to illumination intensities. For further details see the Transactions of the Illuminating Engineering Society, State Codes, etc.

SPACING AND MOUNTING HEIGHT

The spacing and mounting height of luminaires are usually determined by the structural features of the building. It is essential to give these matters serious consideration if the distribution of light is to be satisfactory and objectionable glare is to be avoided. The curve shown on H-79039 gives approximately correct values for spacing and mounting heights for uniform illumination on a working plane 30 in. above the floor.

10 91-82689 TCF

ILLUMINATION CALCULATION

There are two methods commonly used in calculating illumination known as the "lumen method" and the "power method". The symbols used in the formulae for these two methods are these:

L = lumens required per outlet (By referring to table No. 2 the size of lamp may be obtained. It is advisable to use the nearest largest size lamp).

A = area to be lighted

F = foot-candles required (see table No. 1)

N = number of outlets

K = Coef. of utilization (see table No. 3)

This constant also includes a depreciation of 25% to compensate for normal dust and dirt accumulation on lamps and reflector equipment.


W = watts per square foot required per foot-candle
(see H-79724 and H-79725)

P = watts per outlet or size of lamp

THE LUMEN METHOD

$$L = \frac{A \times F}{N \times K}$$

for example, assume a factory floor 40 ft. by 100 ft. or 4000 sq. ft. in area,



ceiling height 18 ft, bays 20 ft. by 20 ft. so that one outlet per bay is permissible. (See curve H-79039)

Space is to be used as a machine shop (fine work) requiring 12 foot-candles. The RLM standard dome and bowl enameled MAZDA lamp selected for the unit. Walls and ceiling medium tone K (see table No. 3) therefore is .40.

$$L = \frac{4000 \times 12}{10 \times .40} \quad (\text{see formula referred to above})$$

$$= 12000 \text{ lumens}$$

Referring to table No. 2 we find nearest standard size MAZDA lamp to 12000 lumens is 750 watts (14500 lumens).

THE POWER METHOD

The power method is based on the power required to produce one foot-candle of illumination, thus:

$$P = \frac{W \times F \times A}{N}$$

Assume the problem referred to above

$$P = \frac{.15 \times 12 \times 4000}{10}$$

= 720 watts—nearest standard size 750 watt lamp

SYSTEMS OF LIGHTING

Systems of lighting have been classified in accordance with the characteristics of light distribution. These systems are known as direct, indirect, semi-indirect and diffusing and have the essential characteristics shown by the chart C-46683.

DIRECT LIGHTING

This system delivers the light directly to the working plane and is, therefore, the most efficient system in terms of actual light delivered per unit of power. Care must be exercised with this system of lighting to avoid objectionable glare. Shadows and lack of diffusion are also likely to result from this method of lighting unless properly designed. Bowl enameled lamps are preferable to clear lamps in equipment of this type in order to obscure the lamp filament from view. This method of lighting is confined largely to factory buildings.

INDIRECT LIGHTING

In this system of lighting the light is directed to the ceiling from which it is diffused to the useful plane. This method of lighting shows the least efficiency in terms of effective lumens per watt but gives the maximum of diffusion and eye protection.

SEMI-INDIRECT LIGHTING

This system embodies the principles of the direct and indirect lighting; part of the light is directed to the ceiling and diffused throughout the room and part delivered directly to the useful plane. By choosing the proper density of glassware the desired proportions of these two components may be obtained for any desired effect. The lumens per watt efficiency is proportional to the relative proportions of the above components as is also the diffusion and degree of eye protection. The system is capable of a wide range of variation and is the most widely used method of lighting buildings other than factory space.

DIFFUSED LIGHTING

In this system of lighting the lamp is entirely enclosed within a diffusing glass envelope. The distribution of light is practically independent of the shape of the globe and gives very satisfactory illumination. The efficiency, eye protection, etc. depend upon the density of the glassware.

The charts shown in Figs. H-79725 and H-79724 have been prepared to indicate the characteristics of typical industrial and general interior luminaires. The essential data are given on these charts to enable one to determine the equipment required for any desired intensity of illumination.

% TOTAL LUMENS OF LAMP

This expresses the percentage of the total lumens generated by the lamp as given in the table of lamp lumens which are delivered by the luminaire; thus,

Efficiency of the R.L.M. standard reflector is 68%

Total lumens of 300 watt bowl enameled MAZDA lamp (See Fig. H-79725) . . . 4500

Therefore, the total lumens delivered by the standard R. L. M. reflector and 300 watt bowl enameled lamp are 68% of 4500 or 3060 lumens.

% UPWARD LUMENS

This expresses the percentage of the lumens delivered by the luminaire which are emitted above the horizontal. This light becomes effective on the working plane only after reflection from ceiling and walls. The upward lumens multiplied by the coefficient of reflection of the reflecting surface (ceiling or walls) is a close approximation of the quantity of light reaching the working plane, Thus,

Lumens of 300 watt clear MAZDA lamp
(see table) 4900

Efficiency of Trojan luminaire
(see chart H-79724) 83%

Total lumens delivered by the
Trojan luminaire 4067

% upward lumens (see chart H-79724) 45%

Total upward lumens (.45 x 4067) 1830

White ceiling (see table of
reflection coefficients
Edison Bulletin LD-102-A) 80%

Upward lumens effective on working
plane (.80 x 1830) 1464

Upward light is also useful in many types of industrial buildings to eliminate the gloomy appearance of a sharp cutoff and dark ceilings.

% DOWNWARD LUMENS

This expresses the percentage of the lumens delivered by the luminaire which are emitted below the horizontal. This light in general is assumed to be effective on the working plane without additional losses due to reflection. Thus,

Total lumens of 300 watt clear lamp (see chart H-79724).....	4900
Efficiency of Ivanhoe Ace luminaire (see chart H-79724).....	70%
Total lumens from luminaire (70% of 4900).....	3430
% Downward lumens (see chart H-79724).....	63%
Downward lumens (.63 x 3430).....	2161

These data referring to lighting are very general and necessarily incomplete. The subject deserves careful consideration and expert counsel and in this connection we offer to architects and engineers the services of our engineers specializing in illuminating problems.

APPENDIX

Table No. 1

	Foot-Candles		
Auditoriums, Churches.....	2	—	4
Armories.....	3	—	5
Exhibition Halls.....	4	—	6
Schools, Class-rooms, study rooms, libraries.....	4	—	8
Stores:			
Show Windows.....	10	—	70
First floor of Department Store, Shop on bright street or corner.....	7	—	10
Other floors of Department Store, Clothing, Drygoods, Haberdashery, Millinery, Jewelry, etc.....	5	—	8
Offices:			
Private General.....	6	—	10
Drafting Room.....	10	—	15
Industrial:			
Yards.....	.25	—	.5
Stairways, Passageways and Corridors.....	1	—	2
Rough Manufacturing on large material such as Foundry; Pottery, Rough Wood Work, Rough Assembling, Forge Shop and Boiler Rooms, etc.....	3	—	6
Medium Rough Manufacturing, such as Rough Machining, Rough Bench Work, Laundries, etc.....	5	—	10
Fine Manufacturing, such as Fine Machining, Machine Wood Work, Pattern and Tool Making, Textile, Press Rooms, Tobacco, Manufacturing, etc.....	8	—	16

The higher values are advisable where the work being done is on dark goods or surfaces.

TABLE NO. 2

Lamp Data—Oct. 1, 1922

MAZDA C LAMPS—110 to 125 Volts

Watts.....	50	75	100	150	200	300	400	500	750	1000
Initial Lumens.....	500	880	1300	2100	3000	4900		9000	14500	20000

220 to 250 Volts

Watts.....	100	200	300	500	750	1000
Total Lumens.....	980	2500	4300	7800	12500	18000

DAYLIGHT MAZDA LAMPS—110 to 125 Volts

Watts.....	75	100	150	200	300	500
Total Lumens.....	600	900	1400	2100	3400	6100

Bowl enamel lamps approximately 8% less than clear lamps in initial lumens.

TABLE NO. 3

UTILIZATION CONSTANTS—PER CENT LUMENS EFFECTIVE

Allowing for Service Depreciation

		Light			Medium			Dark	
Ceiling									
Walls		Lt.	Med.	Dark	Lt.	Med.	Dark	Med.	Dark
Reflector	Mazda C Lamp								
RLM Standard Dome	Clear	.49	.47	.45	.48	.46	.44	.45	.44
RLM Standard Dome	Bowl Enam.	.42	.41	.39	.41	.40	.38	.39	.38
Deep Bowl, Steel	Clear*	.41	.39	.37	.39	.38	.37	.38	.37
Reflector Cap Diffuser	Clear	.35	.34	.32	.34	.33	.31	.32	.31
Deep Bowl, Glass	Bowl Enam.	.40	.38	.36	.37	.35	.33	.32	.31
Diffusing Enclosing Globe	Clear	.37	.34	.32	.35	.33	.31	.31	.30
Light Opal, Semi-Indirect	Clear	.34	.31	.28	.29	.26	.23	.21	.19
Dense Opal, Semi-Indirect	Clear	.29	.27	.25	.22	.20	.19	.16	.14
Totally Indirect	Clear	.27	.25	.23	.20	.18	.16	.12	.10

* Bowl Enameled Lamp, not generally recommended with the deep bowl opaque reflectors on account of the pocketing of light and resultant low utilization.

APPENDIX I

CONTINUATION OF APPENDIX I, PART I, PAGE 1






TABLE 1

Summary of the results of the tests conducted on the specimens of the material under investigation.

Specimen		Material		Test		Result	
No.	Designation	Type	Grade	Method	Load	Displacement	Remarks
1	101	Steel	A36	Tension	100,000	0.001	Yield point reached
2	102	Steel	A36	Tension	200,000	0.002	Ultimate strength reached
3	103	Steel	A36	Tension	300,000	0.003	Fracture occurred
4	104	Steel	A36	Tension	400,000	0.004	Fracture occurred
5	105	Steel	A36	Tension	500,000	0.005	Fracture occurred
6	106	Steel	A36	Tension	600,000	0.006	Fracture occurred
7	107	Steel	A36	Tension	700,000	0.007	Fracture occurred
8	108	Steel	A36	Tension	800,000	0.008	Fracture occurred
9	109	Steel	A36	Tension	900,000	0.009	Fracture occurred
10	110	Steel	A36	Tension	1,000,000	0.010	Fracture occurred

The above table shows the results of the tests conducted on the specimens of the material under investigation. The specimens were tested in tension, and the results show that the material has a yield point of approximately 100,000 pounds, an ultimate strength of approximately 200,000 pounds, and a fracture strength of approximately 1,000,000 pounds.











CHARACTERISTICS OF LIGHTING SYSTEMS

	DIRECT LIGHTING		INDIRECT LIGHTING	SEMI-INDIRECT LIGHTING	DIFFUSED LIGHTING
	OPAQUE	TRANSLUCENT			
TYPICAL DISTRIBUTION CURVES					
LUMENS BARE LAMP	100%	100%	100%	100%	100%
% LUMENS DELIVERED BY LUMINAIRE	64	82	82	83	67
% UPWARD LUMENS	0	22	100	77	39
% DOWNWARD LUMENS	100	78	0	23	61
RELATIVE WATTAGE REQUIRED FOR EQUAL HORIZONTAL ILLUMINATION (corrected)	1.15	1.00	1.50	1.30	1.30

TEST NO 3378
 CHECKED BY W.D.A.
 INSPECTED BY W.D.A.
 W.D.A. RYAN
 ILLUMINATING ENGINEER
 ILLUMINATING ENG. LABORATORY
 GENERAL ELECTRIC CO.
 SCHENECTADY, N.Y.
 C-46683













INDUSTRIAL LIGHTING EQUIPMENT

UNIT					
EQUIPMENT	RLM STANDARD DOME BOWL-ENAMELED MAZDA LAMP, 75-1000 WATTS	GLASS TOP DOME BOWL-ENAMELED MAZDA LAMP, 75-200 WATTS	GLASS STEEL DIFFUSER CLEAR MAZDA LAMP, 75-300 WATTS	FORM 15 NOVALUX CLEAR MAZDA LAMP, 300-300 WATTS	VANTASE GLASS REFLECTOR BOWL-ENAMELED MAZDA LAMP, 25-200 WATTS
DISTRIBUTION CHARACTERISTIC					
% TOTAL LUMENS OF -41°	68	70	67	69	80
% UPWARD LUMENS	0	19	10	0	14
% DOWNWARD LUMENS	100	81	90	100	86
% OF 60° LUMENS	81	65	68	69	59
11.75 SQ. FT. PER 1000 WATTS	0.15	0.19	0.17	0.15	0.16
FOOT-CANDLES PER SQUARE FOOT AT 30' FLOOR AREA REQUIRED PER FOOT-CANDLE OF ILLUMINATION ASSUME A SERVICE FACTOR OF 1.0	0.15	0.19	0.17	0.15	0.16

SIZE OF -41°	DOWNWARD LUMENS	UPWARD LUMENS	TOTAL LUMENS
100	68	32	100
200	136	64	200
300	204	96	300
400	272	128	400
500	340	160	500
600	408	192	600
700	476	224	700
800	544	256	800
900	612	288	900
1000	680	320	1000

W.D. RYAN DIRECTOR
ILLUMINATING ENG. LABORATORY
GENERAL ELECTRIC CO.
SCHENECTADY, N.Y.
H-79723

LUMINAIRES FOR GENERAL ILLUMINATION

FIXTURE					
EQUIPMENT	MANHOE TROJAN UNIT WITH CLEAR MAZDA LAMP 75-300 WATTS	MANHOE ACE UNIT WITH CLEAR MAZDA LAMP 100-300 WATTS	MANHOE HELDON UNIT WITH CLEAR MAZDA LAMP 100-300 WATTS	DUPLEXLITE UNIT WITH CLEAR MAZDA LAMP 75-300 WATTS	FILTERLITE UNIT WITH CLEAR MAZDA LAMP 100-300 WATTS
DISTRIBUTION CHARACTERISTIC					
OVERALL EFFICIENCY COP	83	70	67	75	79
% OF BARE LAMP LUMENS					
% UPWARD LUMENS	45	37	84	80	70
% DOWNWARD LUMENS	55	63	16	20	30
APPROXIMATE WATTS PER SQUARE FOOT PER FOOT-CANDLE	0.15	0.17	0.24	0.21	0.23

THE VALUES GIVEN FOR AVERAGE WATTS PER SQUARE FOOT OF FLOOR AREA REQUIRED PER FOOT-CANDLE OF ILLUMINATION ASSUME THE CEILING AND WALLS ABOVE MAINSCOTTING FINISHED A FLAT WHITE OR CREAM TINT OF APPROXIMATELY 70% COEFFICIENT OF REFLECTION VALUES ALSO INCLUDE SERVICE DEPRECIATION FACTOR OF 30%.


SIZE OF LAMP	BOWL DIMENSIONS	CLEAR
75	8 3/8	900
100	10 1/2	1300
150	13 1/2	2100
200	15 1/2	2700
300	21 1/2	4000
500	27 1/2	6500
1000	34 1/2	10000

FILE NO 4635
CHECKED BY W.H.
INSPECTED BY A.H.R.
DEC 6 1952

W.D. RYAN, DIRECTOR
ILLUMINATING DIVISION
GENERAL ELECTRIC CO.
SCHENECTADY, N.Y.
17-79724

SPACING & MOUNTING HEIGHTS FOR LIGHTING UNITS

HEIGHT FROM FLOOR TO CEILING (INDIRECT & SEMI-INDIRECT).
HEIGHT FROM FLOOR TO UNIT (DIRECT & DIFFUSING UNITS).



DISTANCE BETWEEN OUTLETS - FEET

W.D.A. RYAN DIRECTOR
ILLUMINATING ENG. LABORATORY
GENERAL ELECTRIC CO.
SCHENECTADY, N.Y.

CHECKED BY *W.D.A.*
INSPECTED BY S.L.E.R. (B)

5 JULY 29-1921 REVISED & RETRACED 7/28/22

H-79039